



# CONNECTICUT STATE UNIVERSITY

P.O. BOX 2008 • New Britain, Connecticut 06050 • (203) 827-7700

## RESOLUTION

concerning

AUTHORIZATION TO PERFORM REPAIRS ON FACILITIES SUPPORTED  
BY THE AUXILIARY SERVICES FUND  
AT  
WESTERN CONNECTICUT STATE UNIVERSITY

January 15, 1988

RESOLVED, That Western Connecticut State University is authorized to modify a storage room in the basement of Newbury Hall into a two hour fire rated elevator lobby with fire and smoke detectors in order to comply with the State Fire Code for an estimated cost of \$30,500, the cost to be met from the Connecticut State University Executive Office Auxiliary Services Account.

A Certified True Copy:

Dallas K. Beal  
President